

NEMA Configuration Chart Straight Blade Devices

		15 AMPERE		20 AMPERE		30 AMPERE		50 AMPERE		60 AMPERE	
		RECEPTACLE	PLUG	RECEPTACLE	PLUG	RECEPTACLE	PLUG	RECEPTACLE	PLUG	RECEPTACLE	PLUG
2-POLE 2-WIRE	125V	1-15R ¹ 	B-6 								
	250V		2-15P 	B-6 	B-6 						
	277V					(RESERVED FOR FUTURE CONFIGURATIONS)					
	600V					(RESERVED FOR FUTURE CONFIGURATIONS)					
2-POLE 3-WIRE GROUNDING	125V	5-15R 	B-6, 16, 28 	B-11, 13, 21, 23, 16, 28 	B-16, 24, 28 	B-29 	B-29 	B-30 	B-30 		
	250V	6-15R 	B-16, 18, 28 	B-16, 19, 28 	B-16, 25, 28 	B-29 	B-29 	B-30 	B-30 		
	277V AC	B-20 	B-20 								
	347V AC	B-13 	B-20 								
	480V AC					(RESERVED FOR FUTURE CONFIGURATIONS)					
	600V AC					(RESERVED FOR FUTURE CONFIGURATIONS)					
	125/250V			B-31 	B-31 	B-32 	B-32 	B-32 	B-32 		
	30 250V	11-15R 		11-20R 	11-20P 	11-30R 	11-30P 	11-50R 	11-50P 		
	30 480V					(RESERVED FOR FUTURE CONFIGURATIONS)					
30 600V					(RESERVED FOR FUTURE CONFIGURATIONS)						
3-POLE 4-WIRE GROUNDING	125/250V	14-15R 		14-20R 	14-20P 	B-33 	B-33 	B-33 	B-33 	B-33 	B-33
	30 250V	15-15R 		15-20R 	15-20P 	B-34 	B-34 	B-34 	B-34 	B-34 	B-34
	30 480V					(RESERVED FOR FUTURE CONFIGURATIONS)					
	30 600V					(RESERVED FOR FUTURE CONFIGURATIONS)					
	30Y 120/208V	18-15R 		B-35 18-20R 	B-35 18-20P 			B-35 18-50R 	B-35 18-50P 	B-35 18-60R 	B-35 18-60P
30Y 277/480V					(RESERVED FOR FUTURE CONFIGURATIONS)						
30Y 347/600V					(RESERVED FOR FUTURE CONFIGURATIONS)						
4-POLE 5-WIRE GROGS	30Y 120/208V					(RESERVED FOR FUTURE CONFIGURATIONS)					
	30Y 277/480V					(RESERVED FOR FUTURE CONFIGURATIONS)					
	30Y 347/600V					(RESERVED FOR FUTURE CONFIGURATIONS)					

① Indicates page number where devices are located.
 ② NEMA Number
 Specifications are subject to change without notice.